



AEPL AKSHAT ENGINEERS PVT. LTD.

PRODUCTS FOR BETTER PRESENT & BRIGHT FUTURE

Address: E-315, Lal Kothi Scheme, Behind Vidhan Sabha, Jaipur - 15 Ph.: 0141-2742422

Em@il: info@akshatengineers.com

Website: www.akshatengineers.com

Wall Thickness of UPVC Pipes as per IS 15328

SN	2	4	8
SDR	51	41	34
Pipe Series	S 25	S 20	S 16.5
Outer Dia. (mm)	Wall Thickness & Tolerance (mm)		
110	-	-	3.2 + 0.5
125	-	3.2 + 0.5	3.7 + 0.7
160	3.2 + 0.5	4.0 + 0.6	4.7 + 0.7
200	3.9 + 0.6	4.9 + 0.7	5.9 + 0.8
250	4.9 + 0.7	6.2 + 0.8	7.3 + 1.0
315	6.2 + 0.8	7.7 + 1.0	9.2 + 1.2
400	7.9 + 1.0	9.8 + 1.2	11.7 + 1.4
500	9.8 + 1.2	12.3 + 1.4	14.6 + 1.7
630	12.3 + 1.2	15.4 + 1.7	18.4 + 1.9

Note: The above dimensions are as mentioned in IS 15328: UNPLASTICIZED NON-PRESSURE POLYVINYL CHLORIDE (PVC-U) PIPES FOR USE IN UNDERGROUND DRAINAGE AND SEWERAGE SYSTEMS. The above values are for reference only and the users are requested to reverify these values before using them. Due to typing mistake if any value (s) is incorrect, then Akshat Engineers Private Limited cannot be held responsible for any consequential damages incurred by the user due to the use of these above-mentioned values.